

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

FIRE CODE

ITEM	POSITION	DISPOSITION
F8-06/07 PC - #1	Oppose Public Comment	<u>Reason:</u> Doesn't recognize Fire Official Authority <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F14-06/07 PC - #1	Support Modification by Public Comment	<u>Reason:</u> Editorial <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F14-06/07 PC - #2	Support Modification by Public Comment	<u>Reason:</u> Editorial <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F18-06/07 PC - #1	Oppose Support Committee Action for Disapproval	<u>Reason:</u> We like the word INIMICAL <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F18-06/07 PC - #2	Oppose Support Committee Action for Disapproval	<u>Reason:</u> We like the word INIMICAL <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F19-06/07	Oppose Support Committee Action for Disapproval	<u>Reason:</u> Agree with Committee reasons. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F25-06/07	Oppose Support Committee Action for Disapproval	<u>Reason:</u> Further limits section to candles so the code will not address items like sterno. OCFA – Current language gives us more enforcement options & allows us to address unidentified open flame devices. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F28-06/07	Oppose Public Comment	<u>Reason:</u> Modification is poorly worded, not code format Contact proponent about a friendly modification for next round. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
F29-06/07	Oppose Public Comment	<input type="checkbox"/> DISAPPROVAL <u>Reason:</u> “Enhance is a better word to use than “Secure”. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F32-06/07	Oppose Support Committee Action for Disapproval	<u>Reason:</u> Support Committee action. OCFA – How does this increase security? See reasons under F19 <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F33-06/07 PC - #1	Oppose Public Comment #1	<u>Reason:</u> Like the concept. Good intent, poor execution, not ready for prime time IMO. Public comments did not address the reason for disapproval <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F33-06/07 PC - #2	Oppose Public Comment #2	<u>Reason:</u> Like the concept. Good intent, poor execution, not ready for prime time IMO. Public comments did not address the reason for disapproval <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F37-06/07	Oppose Support Committee Action for Disapproval	<u>Reason:</u> Public comment is still a bad idea. OCFA – Is in support, you can have it on site on disk format. Leave it up to the jurisdiction. DISCUSS IN CAUCUS <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F40-06/07, Part I	Support Public Comment	<u>Reason:</u> Reasons stated in Public Comment. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F40-06/07, Part II PC - #1	Support Public Comment	<u>Reason:</u> N-Reasons stated in Public Comment. OCFA – Seems to just be a “shot” at the process rather than clarification. DISCUSS IN CAUCUS <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F40-06/07 Part II	Support Public Comment	<u>Reason:</u> Reasons state in Public Comment <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
PC - #2		<input type="checkbox"/> DISAPPROVAL
F42-06/07, Part I	Oppose Support Committee Action	<u>Reason:</u> Reasons stated in Committee Action <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F42-06/07, Part II	Oppose Support Committee Action	<u>Reason:</u> Reasons stated in Committee Action <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F46-06/07 HazMat	N-Oppose S-Support	<u>Reason:</u> N-Allows a fuel tank inside a building w/o ventilation, remote filling, and ignores MAQ's. S-Allows a flexibility in fuel tanks for generators inside a building. DISCUSS IN CAUCUS <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F220-06/07 HazMat	Oppose Public Comment for Modification	<u>Reason:</u> Allows for 36,000 gals. of fuel at the ground floor of a building, claiming the code change is made for "homeland security" related items. Proponent did not address committee concerns. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F48-06/07	Oppose Public Comment to Modify Proposal	<u>Reason:</u> Regardless if it is an appendix, still should be placed in the Electric Code. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F53-06/07	Support Modification to Proposal	<u>Reason:</u> Public comment fixes committee concerns. Support revision. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F54-06/07	Support Proposal As Submitted	<u>Reason:</u> Talk to Haz Mat and get another opinion, seems expensive. Possibly contact proponent. OCFA – Opposed, Early warning supervised systems are critical for employee and community safety. Support floor action. DISCUSS IN CAUCUS <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F57-06/07	Oppose Public Comment for Modification	<u>Reason:</u> Public comment fixes 703.1 but 701.2 belongs in Chapter 1 and expands the scope of this chapter. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F58-06/07	Oppose Public Comment for	<u>Reason:</u> Public comment does not change original reasons for opposition.

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
	Modification	<u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F59-06/07	Support Assembly Action for Disapproval	<u>Reason:</u> We supported this item in Orlando, continued support for Rochester. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F60-06/07	Oppose Public Comment for Modification	<u>Reason:</u> N-Not necessary for the AHJ, presently have authority to request UL listing information to ensure product is used in conformance to testing and approvals regardless of occupancy. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F67-06/07 PC - #1	Oppose Support Committee Action	<u>Reason:</u> N-Unenforceable requirement <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F67-06/07 PC - #2	Oppose Support Committee Action	<u>Reason:</u> N-Support Committee comments. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F75-06/07	Oppose Public Comment	<u>Reason:</u> N-Prefer F-76 language <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F76-06/07	Oppose Public Comment	<u>Reason:</u> N-Ask proponent to introduce next round with consistent language to F-67. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F79-06/07	Oppose Support Committee Action	<u>Reason:</u> No statistical information provided. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F81-06/07 E&D	Oppose Public Comment For Modification	<u>Reason:</u> N-A reference list "not" a code item. S-Table 901.6.1 refers to NFPA Std's w/respective maintenance items. Std's can change any code cycle & conflict with I-Code list. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
F85-06/07 E&D	N-Oppose S-Support	<u>Reason:</u> N-Partial sprinklers are to be installed in Group A's. S-Modified text addresses committee comments. DISCUSS IN CAUCUS. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F94-06/07 E&D	Oppose Public Comment for Modification	<u>Reason:</u> N-Allows heat detection in lieu of sprinklers in sports arenas. S-Participant sports arenas could include smaller gymnasiums where sprinkler protection is effective due to ceiling heights & property protection is expected based upon NFPA 13. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F221-06/07 E&D	Support Public Comment for Modification	<u>Reason:</u> N-Supports NIST WTC findings for terrorism resistance. S-Support as Public Comments. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F100-06/07 E&D	N-Support S-Oppose	<u>Reason:</u> N-Original language works. S-Modified text limits to §907 required systems & by default excludes voluntary alarm systems. Long standing E&D issue w/work developing on appropriate "definitions" to differentiate alarm systems from monitoring systems. DISCUSS IN CAUCUS. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F102-06/07 E&D	Support	<u>Reason:</u> N-Clarifies that the inspections form lists the person & company performing the work. S-Support public comments. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F113-6/07, Part I PC - #1 E&D	Oppose Committee Action for Approval	<u>Reason:</u> N-Installs duct detectors in both sides of ducting. S-Detection added on supply side. General note for entire proposal: E&D has been working on ways to eliminate the use of air-sampling tube duct detectors for a long time. The detectors have a flow by the fact that they will not detect smoke when units are below listed CFM ratings w/adjustments to economizer modes. Smoke will still have potential to migrate to other rooms/areas due to pressure differences in rooms. Duct detectors in general also require more maintenance & have a higher degree of nuisance alarms regardless of which side on the duct systems. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F113-06/07 Part I PC - #2 E&D	Oppose Public Comment for Modification	<u>Reason:</u> N-Increases threshold of duct detectors to 15,000 CFM. S-Still includes 15,000 CFM increase. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
F113-06/07 Part I PC - #3 E&D	Support Public Comment Oppose Committee Action	<u>Reason:</u> N-Leaves duct detectors in the returns only. S-For reasons stated in Public Comments. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F113-06/07 Part I PC - #4 E&D	Support Public Comment Oppose Committee Action	<u>Reason:</u> N-Leaves duct detectors on returns only. S-For reasons stated in Public Comments. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F113-6/07, Part II PC - #1 E&D	Oppose Support Assembly Action for Disapproval	<u>Reason:</u> N-Increases CFM to 15,000 for duct detectors. S-CFM increase & adds to supply side. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F113-06/07 Part II PC - #2 E&D	Oppose Support Assembly Action for Disapproval	<u>Reason:</u> N-Code does not already require duct detectors in the exhaust ducts. S-CFM increase & adds to supply side. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F113-06/07 Part II PC - #3 E&D	Support Assembly Action for Disapproval	<u>Reason:</u> N-Leave code as is. S-For reasons stated in Public Comment. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F113-06/07 Part II PC - #4 E&D	Support Assembly Action for Disapproval	<u>Reason:</u> N-No need for more redundancy. S-For reasons stated in Public Comment. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F122-6/07, Part I PC - #1 E&D	N-Oppose S-Support	<u>Reason:</u> N-Duct detectors to send alarm signal in R's. Requires detection in high pile storage, requires duct detection in both return/exhaust air. S-For reasons stated in Public Comment. DISCUSS IN CAUCUS <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F122-06/07 Part I	Support Public Comment for Modification	<u>Reason:</u> N-Allows deletion of smoke alarm for control panel when sprinklered. S-For reasons stated in Public Comment. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
PC - #2 E&D		<input type="checkbox"/> DISAPPROVAL
F122-06/07 Part I PC - #3 E&D	Support Public Comment for Modification	<u>Reason:</u> N-Deletes pull stations when fully sprinklered & occupant notification is installed. S-For reasons stated in Public Comments <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F122-06/07 Part I PC - #4 E&D	Oppose Public Comment for Modification	<u>Reason:</u> N-Deletes fire alarms systems in R-2 when fully sprinklered. S-Not limited to manual fire alarm system as original code intended & extends to include fire alarm systems. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F122-6/07, Part II E&D	Oppose Public Comment for Modification	<u>Reason:</u> N-No need shown for reinserting existing building code. S-No need shown for reinserting existing building code. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F124-06/07 E&D	Oppose Public Comment Support Committee Action	<u>Reason:</u> N/S-Eliminates smoke vents for F-1 & S-1 & increases travel distances. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F125-06/07 E&D	Oppose Public Comment Support Committee Action	<u>Reason:</u> N/S-Eliminates smoke vents for F-1 & S-1, high piled storage & increases travel distances. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F129-06/07 E&D	Support Public Comment	<u>Reason:</u> N-Per Std. UL793 the maximum temp. fusible link can be in 286° with sprinkler heads being the same temp. S-Fore reasons stated by proponent. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F130-06/07 PC - #1 E&D	Oppose Support Committee Action for Disapproval	<u>Reason:</u> N/S-Eliminates smoke cents for F-1 & S-1 & for high piled storage. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F130-06/07	Oppose Support	<u>Reason:</u> N/S-Eliminates smoke cents for F-1 & S-1 & for high piled storage.

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
PC - #2 E&D	Committee Action For Disapproval	<u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F132-06/07 PC - #1 E&D	Support Public Comment for Approval as Submitted	<u>Reason:</u> N-Changes code official to fire chief & is inconsistent w/ other sections of code. S-For reasons stated in Public Comment. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F132-06/07 PC - #2 E&D	Support Public Comment for Approval as Submitted	<u>Reason:</u> N-Changes code official to fire chief & is inconsistent w/ other sections of code. S- For reasons stated in Public Comment. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F132-06/07 PC - #3 E&D	Support Public Comment for Approval as Submitted	<u>Reason:</u> N-Changes code official to fire chief & is inconsistent w/ other sections of code. S- For reasons stated in Public Comment. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F133-06/07 PC - #1 E&D	Support Public Comment for Approval as Submitted	<u>Reason:</u> N-Changes code official to fire chief. S-For reasons stated in Public Comments. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F133-06/07 PC - #2 E&D	Support Public Comment for Approval as Submitted	<u>Reason:</u> N-Changes code official to fire chief. S-For reasons stated in Public Comments. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F133-06/07 PC - #3 E&D	Support Public Comment for Approval as Submitted	<u>Reason:</u> N-Changes code official to fire chief. S-For reasons stated in Public Comments. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F136-06/07	Oppose Public Comment for Modification	<u>Reason:</u> N-No reason to speak, but oppose the public comment, word smith... worth it? S-Modified text is unnecessary as the releasing hardware for unoccupied areas is redundant to requirements for "common knowledge" hardware in occupied areas. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F139-06/07	Oppose Support Committee	<u>Reason:</u> Support committee reasons. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
	Action for Disapproval	<input type="checkbox"/> DISAPPROVAL
F140-06/07	Support Public Comment for Modification	<u>Reason:</u> Commenter's reasons appear to have addressed committee's concerns. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F147-06/07 HazMat	Withdrawn	<u>Reason:</u> NORCAL Code Change. Technical flaws discovered during review period. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F155-06/07 HazMat	No Position	<u>Reason:</u> <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F156-6/07, Part I HazMat	Support Public Comment for Modification	<u>Reason:</u> <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F156-6/07, Part II HazMat	Support Public Comment for Modification	<u>Reason:</u> <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F229-06/07 HazMat	N-Support S-Opposes	<u>Reason:</u> S-Better served in a different code. DISCUSS IN CAUCUS <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F158-06/07 E&D	Oppose Public Comment for Approval as Submitted	<u>Reason:</u> N/S-Removes smoke/heat vents from the code. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F165-06/07	Support Public Comment for Modification	<u>Reason:</u> Author cleans up his own language. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F218-06/07 HazMat	Support Public Comment for Modification	<u>Reason:</u> S-Provides clarity to the code section. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
F224-06/07 HazMat	Support Public Comment for Modification	<u>Reason:</u> S-Addresses committee's concerns. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F231-06/07 HazMat	Support Public Comment for Modification	<u>Reason:</u> N-Clarifies what controls are fail-safe. S-Word-smithing clarity <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F173-06/07 HazMat	Support Public Comment for further Modification	<u>Reason:</u> <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F175-06/07 HazMat	Opposed Public Comment, Support Committee for Disapproval	<u>Reason:</u> N-Agreement w/South. S-Proponent only addressed a portion of the committee's concerns. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F177-06/07	Neutral	<u>Reason:</u> California will not be adopting this section. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F188-06/07 HazMat	Support Public Comment for Modification & Approval	<u>Reason:</u> S-Language clean-up <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F219-06/07 HazMat	Oppose Public Comment and Support Committee Action	<u>Reason:</u> N-Prefer F218 <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F190-06/07	Support Public Comment for Modification and Approval	<u>Reason:</u> Acceptable levels, consistent with DHS and JCAHO standards. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F200-06/07 HazMat	Support Public Comment for Modification	<u>Reason:</u> See Commenter's Reasons! <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL

CALIFORNIA FIRE CHIEFS ASSOCIATION
INTERNATIONAL CODE COUNCIL
2006/07 CODE DEVELOPMENT CYCLE

ITEM	POSITION	DISPOSITION
F205-06/07 HazMat	Wait	<u>Reason:</u> N-Item is about LOX for home health care. Speak with author. <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F210-06/07	Support Public Comment for Modification and Approval	<u>Reason:</u> Request proponent to consider Appendix <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F222-06/07 HazMat	Support Public Comment for Modification and Approval	<u>Reason:</u> <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL
F223-06/07 HazMat	Support Public Comment for Modification	<u>Reason:</u> <u>Assembly Action:</u> <input type="checkbox"/> APPROVAL <input type="checkbox"/> DISAPPROVAL